CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
0843-CPR-1397

Issue date
2024-11-22

Issue No.
2

Re-Issue date
2025-09-08

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer:
Astroflame Fireseals Ltd

Address:
Intumescent House, Unit 8 The I.O Centre, Stephenson Road, Fareham, Hampshire, PO15 5RU

Product:
Astro FRA Socket Box Insert

Places of production:
A/028

Harmonized requirements
EAD 350454-00-1104, September 2017

Scope of Certificate
0843-UKTA-24/0047, issued on 2025-09-08

On behalf of the Head of Approved Body:

Chris Johnson

Issued by UL International (UK) Ltd, Approved Body 0843.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in UKTA 24/0047 of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the EAD, UKTA 24/0047, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

UKAS PRODUCT CERTIFICATION
4705

UL Solutions
Form-ULID-006104 V9.0

UL International (UK) Limited
Unit 1-4 Horizon, Kingsland Business Park, Wade Rd.,
Basingstoke. RG24 8AH United Kingdom

© 2025 UL LLC. All rights reserved.

Detailed information sheet:

Product Reference:	Astro FRA Socket Box Insert
Type:	Firestop – Insert used as a penetration seal
Description:	The Astro FRA Socket Box Insert is a fire resistant, mineral fibre, socket box insert used to limit the passage of fire and smoke through the cavity where a socket box penetrates a wall. The Astro FRA Socket Box Insert is supplied in single and double pre-formed sizes for 35mm and 47mm back box depths. The Socket Box Insert is push fitted into the metal or plastic back boxes with the flange holding the insert in position.
Key Performance parameters:	See 0843-UKTA-24/0047
Identification and intended use	Label

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, technical datasheet and UKTA.
Limitations	See Technical Data Sheet and the UKTA
UL Report:	4791840391

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

UL International (UK) Limited
Unit 1-4 Horizon, Kingsland Business Park, Wade Rd.,
Basingstoke. RG24 8AH United Kingdom

© 2025 UL LLC. All rights reserved.